

White County, Georgia

ADDENDUM # 1

August 9, 2023

Roofing Replacement Project# 2023-RFP-RR07192023

This addendum is issued to change or clarify the proposal documents associated with the Roofing Replacement RFP, Issued July 19, 2023.

Q. Re: the Spec #2.0 Scope of Work, the “Rolled Roofing” referenced for the Ambulance Garage only is to be removed & replaced. Based on the Appendix C specification, would like to confirm that we would need to install a 2 layer type Mod. Bit rolled Roofing?

A. YES, THAT IS CORRECT!!!

Q. On the Ambulance garage building, do we need to replace the metal cupping with new?

A. YES

Q. Are we doing the flat surface area on top of the Ambulance garage building and not just the shingles visible from the ground?

A. YES

Q. On the Health department building, are we changing any of the metal parts of the roof? If so, which area?

A. NO, none of the metal roofing will be replaced.

Q. In regards to the E-verify, we have less than 10 employees which should mean this would not be applicable to us. Would appreciate your confirmation on that.

A. Yes, it would mean exempt. You would just need to complete the “E-verify Exempt” form.

Note: A signed acknowledgement of this addendum must be received by the White County Purchasing Assistant and attached to your proposal response.

Vendor Name: _____

Address: _____

Email: _____

Authorized Signature: _____ Date: _____

Name (Printed): _____ Title: _____