



## **White County Board of Commissioners**

*Project # 2023-WCFS-00-1-A*

Addendum [11/23/2023]

**RFP Closing Date: Tuesday, November 28, 2023**  
**Time: 2:00 PM**

This addendum is issued to change or clarify the proposal documents associated with Invitation to Bid: Fire Station 4 and Fire Station 6 (Re-solicitation).

***Note: A signed copy of this addendum must be submitted with your proposal response.***

### Notes from Pre-Bid Meeting

1. All new walls constructed need to be insulated.
2. Any wall relocations need to be insulated.
3. Before the pre-coverup inspection, we will perform a walkthrough to verify placement of fixtures.
4. Existing propane line feeding dayroom at Station 6 will need to be capped off.



## Acknowledgement of Addendum

*Project # 2023-WCFS-001-A*

I, the undersigned, hereby confirm that I have read and understood the attached addendum dated 11/23/2023. I acknowledge that this addendum is an integral part of the Invitation to Bid to which it pertains.

Name: \_\_\_\_\_

Phone Number: \_\_\_\_\_

Address: \_\_\_\_\_

\_\_\_\_\_

Email: \_\_\_\_\_

Authorized Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Printed Name: \_\_\_\_\_ Title: \_\_\_\_\_