

White County, Georgia

ADDENDUM # 1

MARCH 8, 2024

INVITATION TO BID RE-SOLICITATION FIRE STATION 4 AND FIRE STATION 6 RENOVATIONS

This addendum is issued to change or clarify the proposal documents associated with the renovations to Fire Station 4 and Fire Station 6, Issued February 9, 2024.

Q. Is a **COMMERCIAL** general contractor license required? (state law says yes)

A. Yes, per the bid invitation, the contractor will comply with all State and Federal laws, rules, and regulations.

Q. Flooring Moisture Barrier (not used in specified product)

The flooring specification is a glue down product which does not use a moisture barrier that a floating floor would use. A floating floor is not generally used in commercial spaces.

A. It won't be necessary to put down a moisture barrier.

Q. Cabinets Specifications submitted for Clarity -

Shaker Style - Gray in color (to contrast with flooring color of Dark Amber)

Solid Hardwood Door Frames and face frames with plywood center panels

Cabinet boxes with 1/2" plywood, tops, sides and bottoms.

5/8" hardwood dovetail drawer boxes with 1/2" bottoms.

3/4 plywood shelves

Cabinet boxes are to be matched stained.

6-way adjustable soft close under mount drawer glides with full extension
Soft close door hinges
Door and drawer pull allowance should be included of 5\$ each for materials.

A. Those specs will be acceptable for each bidder, however, Chief LeFevre will want to check the color before committing to gray.

Q. The spec's do not mention any new cabinets in the Phase 1 (EMS Area), please confirm.

A. The ONLY kitchen cabinet work at Station 4 will be in Phase II area.

Q. Does the second site visit change the deadline?

A. No, the deadline for bids due remains the same. Due no later than 2:00 pm, March 8th, 2024.

Note: A signed acknowledgement of this addendum must be received by the White County Purchasing Assistant and attached to your proposal response.

Vendor Name: _____

Address: _____

Email: _____

Authorized Signature: _____ Date: _____

Name (Printed): _____ Title: _____